PARSONS DRILLING INC

Invoice

Contractor's License #29064
P.O. BOX 1265
FALLON, NV 89407-1265

DATE	INVOICE #
10/9/2025	115018c

BILL TO
Berney Realty 1870 W Williams Ave Fallon, NV 89406

P.O. NO.	TERMS	DUE DATE
12565 Silver Sage	Due on recpt	10/9/2025

DESCRIPTION	QTY	RATE	AMOUNT
Flow Test Work Address: 12565 Silver Sage Trail. Stagecoach	1	475.00	475.00
Nevada Analytical Labs Drinking Water Test	1	240.00	240.00

1-1/2% Interest Monthly 18% Yearly
We Appreciate Your Business

Total $715.00

PARSONS DRILLING, INC.

(775) 867-3009

Nevada License
#29064 - $1,000,000
California License
#830264

403 Mclean Rd.
Fallon, NV 89406
(775) 867-3009

Customer Name Berney Realty- Loretta Date: 10/7/2025

Job Location: 12565 Silver Sage Trail, Stagecoach, NV

Pump Type & Make: Submersible 3W Pump Volts (Pump On): 236.2

Pump HP: 2 HP Pump Running Amps: Y:7.82

Pump Volts (Pump Off) 239.6 Pump Running Amps: B: 7.80

R: 7.80

Estimated Well Depth Measured: 444' Casing Size: 6" Pressure Tank PSI:44

Static Water Level: 190' Drop Pipe:1-1/4" PVC Well Wire: 10/3 FJ

OHMS: YB: 2.7 YR: 2.7 BR:2.7

Pumping Flow Rate: 13.57gpm Pumping Static: 281'

Pump Depth: 320' Pump Cut In Pressure: N/A PSI

SubDrive 20 VFD Pump Cut Out Pressure: N/A PSI

Start Time: 2:15 P.M. End Time : 3:15 P.M.

Test Pump Used: Owners Pump Used: X

Comments/Recommendations: Well Pumped 13.57 gpm for 1hr

Flow Test taken at Hose Bibb. One Water sample taken from R/O system

Technician: Gary Stutsman

Disclaimer: This test represents the ability of the well to produce water at the time of the testing only. There are no guarantees on the water quality that the well produces.

PARSONS DRILLING, INC.
(775) 867-3009

Nevada License
#29064 - $1,000,000
California License
#830264


403 Mclean Rd.
Fallon, NV 89406
(775) 867-3009

Customer Name: Berney Realty- Loretta Date: 10/7/25


Job Location: 12565 Silver Sage Trail, Stagecoach, NV



Well Head



Pressure System



Test Pumping Flow Meter



Test Pumping Flow